## **DATASHEET - BF-U-5/165-A**



Complete flush-mounted flat distribution board, white, 33 SU per row, 5 rows, type  $\boldsymbol{\mathsf{A}}$ 



Part no. BF-U-5/165-A Catalog No. 240746

<b>D</b>			
	livery	nro	aram
שש	HVGIV	piu	yı am

Donvoly program			
Basic function			Basic device
Product function			Installation distribution boards
Product range			BF flat DBO
Design			Hollow wall Flush mounted
Installation site			Indoor
Type of installation			Hollow-wall mounting and flush mounting
Door/Flap			White
Degree of Protection			IP30
Colour			White
Module rack			Rail-frame
Shroud for protection against accidental contact			Metal
Rows	Count		5
Module units per row			33
Description			IP30 Protection Class I Steel sheet enclosure white (RAL 9016)
Cable entries			Cable entries on top and bottom
PE and N terminals design			Screw terminals
PE and N terminals	Number x cross- sectional area	mm <sup>2</sup>	N: 2 x 25 + 9 x 16 PE: 2 x 25 + 74 x 16
Equipment supplied			Wall trough with door frame Door with three-point turn-lock DIN rail mounting frame Front plates Neutral-/protective conductor terminal

#### **Technical data**

#### General

donorui				
Standards			IEC/EN 61439-1, IEC/EN 61439-3, IEC/EN 62208	
RoHS (in accordance with Directive 2002/95/EC of the European Parliament and Council)			conform	
Ambient temperature		°C	-5 - +40	
Degree of Protection			IP30	
Protection class			I (earthed)	
Rated operational voltage	Ue	V AC	415	
Rated frequency	f	Hz	50/60	
Material characteristics				
Material			Sheet steel, powder-coated	
Colour			white (RAL 9016)	
Material properties				
Mechanical				
Impact resistance			IK07	

# Design verification as per IEC/EN 61439

Technical data for design verification			
Heat dissipation, at an ambient temperature of 35°C, delta T: 20 degrees in top of the enclosure, calculated as per IEC 60890			
Individual enclosure, flush mounting	$P_{V}$	W	68
Heat dissipation, at an ambient temperature of 35°C, delta T: 35 degrees in top of the enclosure, calculated as per IEC 60890			

IEC/EN 61439 design verification  10.2 Strength of materials and parts  10.2.2 Corrosion resistance  10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  10.2.6 Mechanical impact 10.2.7 Inscriptions  10.3 Degree of protection of ASSEMBLIES  Page Meets the product standard's requirements.  Not relevant to indoor installations.  IKO7  Meets the product standard's requirements.  IKO7  Meets the product standard's requirements.	
10.2.2 Corrosion resistance  Meets the product standard's requirements.  10.2.3.1 Verification of thermal stability of enclosures  Meets the product standard's requirements.  10.2.3.2 Verification of resistance of insulating materials to normal heat  Meets the product standard's requirements.  Not relevant to indoor installations.  Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact  IK07  Meets the product standard's requirements.	
10.2.3.1 Verification of thermal stability of enclosures  10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  Not relevant to indoor installations.  10.2.5 Lifting  Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact  IK07  10.2.7 Inscriptions  Meets the product standard's requirements.  Meets the product standard's requirements.	
10.2.3.2 Verification of resistance of insulating materials to normal heat  10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  10.2.5 Lifting  Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact  IK07  Meets the product standard's requirements.  Meets the product standard's requirements.  Meets the product standard's requirements.	
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  Not relevant to indoor installations.  10.2.5 Lifting  Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact  IK07  10.2.7 Inscriptions  Meets the product standard's requirements.	
and fire due to internal electric effects  10.2.4 Resistance to ultra-violet (UV) radiation  Not relevant to indoor installations.  10.2.5 Lifting  Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact  IK07  10.2.7 Inscriptions  Meets the product standard's requirements.	
10.2.5 Lifting Does not apply to enclosures without lifting aids.  10.2.6 Mechanical impact IK07  10.2.7 Inscriptions Meets the product standard's requirements.	
10.2.6 Mechanical impact IK07  10.2.7 Inscriptions Meets the product standard's requirements.	
10.2.7 Inscriptions  Meets the product standard's requirements.	
10.3 Degree of protection of ASSEMBLIES IP30	
10.4 Clearances and creepage distances Is the panel builder's responsibility.	
10.5 Protection against electric shock < 0.1  \Omega\$; meets the product standard's requirements.	
10.6 Incorporation of switching devices and components Is the panel builder's responsibility.	
10.7 Internal electrical circuits and connections Is the panel builder's responsibility.	
10.8 Connections for external conductors Is the panel builder's responsibility.	
10.9 Insulation properties	
10.9.2 Power-frequency electric strength $U_i$ = 415 V AC	
10.9.3 Impulse withstand voltage Does not apply to basic enclosures as defined in EN 62208.	
10.9.4 Testing of enclosures made of insulating material Does not apply to metal enclosures.	
10.10 Temperature rise  The panel builder is responsible for the temperature rise calculation. provide heat dissipation data for the devices.	Eaton will
10.11 Short-circuit rating Is the panel builder's responsibility.	
10.12 Electromagnetic compatibility Is the panel builder's responsibility.	
10.13 Mechanical function Meets the product standard's requirements.	


## **Technical data ETIM 7.0**

Distribution boards (EG000023) / Small distribution board (EC000214)

Electric engineering, automation, process control engineering / Electrical installation, device / Electrical distribution system (incl. small distribution board) / Small distribution board (ecl@ss10.0.1-27-14-24-09 [ACN387011])

(ecl@ss10.0.1-27-14-24-09 [ACN387011])			
Mounting method			Flush mounted (plaster)
Number of rows			5
Width in number of modular spacings			33
Type of cover			Door
Cover model			Closed
Transparent cover/door			No
Material housing			Steel
Height	1	mm	920
Width	1	mm	750
Depth	1	mm	136
Built-in depth	1	mm	127
Internal depth	1	mm	127
DIN-rail			Yes
With mounting plate			No
Extension possible			No
EMC-version			No
Colour			White
RAL-number			9016
Degree of protection (IP)			IP30
With lock			No
Type of closure			Other

## **Dimensions**



# Additional product information (links)

Product overview (Web)

http://www.eaton.eu/DE/Europe/Electrical/ProductsServices/Residential/index.htm